



Republika ng Pilipinas
Lungsod Quezon
SANGGUNIANG PANLUNGSOD
(City Council)

PR98-267

17th Regular Session

RESOLUTION NO. SP 10607, S-98

A RESOLUTION AUTHORIZING THE QUEZON CITY GENERAL HOSPITAL (QCGH), TO UTILIZE/USE PART OF ITS HOSPITAL DEVELOPMENT FUND (HDF) AMOUNTING TO FIVE MILLION PESOS (P5,000,000.00) FOR THE IMPROVEMENT OF THE HOSPITAL'S ELECTRICAL SYSTEM AND INSTALLATION OF FIRE SAFETY MEASURES SUBJECT TO EXISTING ACCOUNTING AND AUDITING RULES AND REGULATIONS.

INTRODUCED BY COUNCILOR GODOFREDO T. LIBAN II.

Co-Introduced by Councilors Vincent P. Crisologo, Elizabeth A. Delarmente, George M. Canseco, Rommel R. Abesamis, Ma. Fresca M. Biglang-awa, Marciano P. Medalla, Eric C. Medina, Julian M.L. Coseteng, Nanette Castelo Daza, Jesus C. Suntay, Marcel C. Rillo, Alma F. Montilla and Almario E. Francisco.

WHEREAS, the Quezon City General Hospital, in order to comply with the new standards required by the Bureau of Licensing and Regulations, Department of Health, has to upgrade its facilities to ensure the safety of the patients, hospital personnel and the general public.

WHEREAS, the Quezon City Fire Station, after thorough inspection of the hospital building and premises, requires the Quezon City General Hospital to have a Fire Safety Certificate of which the issuance can be done only upon compliance with certain requirements such as fire alarm system, additional automatic emergency lights, additional exit (luminous) signs, smoke and heat detectors, alternate exit door at the medical section, window opening at the OB ward and install 44 additional portable fire extinguishers;

WHEREAS, the City Engineer's Office Industrial Safety Division, after thorough inspection of the mechanical equipment and devices like dumbwaiter, electrical generator, air conditioners, water pumps, x-ray machine and other medical equipment, requires the issuance of PERMIT TO OPERATE these mechanical devices duly signed by a professional mechanical engineer;

WHEREAS, the estimated cost of all these improvements for fire safety, industrial safety and electrical safety made by the agencies concerned amounted to Five Million Pesos (P5,000,000.00);

914


WHEREAS, the Quezon City General Hospital has accumulated unexpended allotments and income worth Five Million Pesos (P5,000,000.00) in its Hospital Development Fund which could be used for such purpose;

NOW, THEREFORE,


BE IT RESOLVED BY THE CITY COUNCIL OF QUEZON CITY IN SESSION ASSEMBLED, to authorize, as it does hereby authorize, the Quezon City General Hospital (QCGH), to utilize/use part of its Hospital Development Fund (HDF) amounting to Five Million Pesos (P5,000,000.00) for the improvement of the Hospital's electrical system and installation of fire safety measures, subject to existing accounting and auditing rules and regulations.

RESOLVED, FURTHER, that the Director of the Quezon City General Hospital shall submit to the City Council of Quezon City a report of all disbursement made pursuant to this resolution immediately after spending the entire subject amount.

ADOPTED : December 1, 1998.


BAYANI V. HIPOL
Acting Presiding Officer

ATTESTED :


EUGENIO V. JURILLA
City Council Secretary

marisa/rmaya*

9/10

4